

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

April 17, 2013

ECOWATER SYSTEMS LLC MARGARET BICKING 1890 WOODLANE DR WOODBURY MN 55125 SEARS BRANDS MANAGEMENT CORPORATION MARGARET BICKING 1890 WOODLANE DRIVE WOODBURY MN 55125

Re: Description: WATER TREATMENT DEVICE - ACTIVATED CARBON Manufacturer: SEARS BRANDS MANAGEMENT CORPORATION Froduct Name: KENMORE CENTRAL WATER FILTRATION SYSTEM

Model Number(s): 625.382080 Product File No: 20130081

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2018.

This approval supersedes the approval issued on July 10, 2008 under product file number 20080309.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
 contaminants and/or substances as specified in this approval letter when the product is installed and
 maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- Operation of these devices at flow rates above the rated service flow rates specified within this
 approval letter are not supported or acknowledged by this approval. The rated service flow rates are
 the flow rates at which these devices were tested.

Because the level of treatment obtained is, in part, a function of how long the water is in contact with the treatment media within these devices, arbitrary increases in the flow rates above the rated service flow rates may compromise the quality of the treated water.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 13008101.DOC

Sears Brands Management Corporation April 17, 2013

Page 2 of 2

Product File No.: 20130081

AESTHETIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20130081 TABLE 1 OF 1

Flow Rates: 22.7 liters per minute (lpm) @ 69 kPa [6 gallon per minute (gpm) @ 10 pounds per

square inch - gauge (psig)]

Capacities: 2,157,685 liters (I) [570,000 gallons (gals.)]

Tested Contaminant	Influent Challenge (mg/l) 1
Chlorine (free)	2.0 ± 10%

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with NSF *International* Standard 42. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by \geq 50%; meeting the free chlorine reduction requirements also qualifies the device for the reduction of aesthetic, organic, taste and odor reduction (e.g. geosmin, methylisoborneol); this does not include hydrogen sulfide.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)

± = plus or minus

≥ + greater than or equal to

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter Plumbing Product Reviewer Department of Safety and Professional Services Division of Industry Services Bureau of Technical Services (608) 267-1401 Phone (608) 266-2602 Fax glen.schlueter@wi.gov E-mail